

Certificate of Product Approval

Certificate Number: 682e-(cl-1)

Issue: 02

CONTEXT PLUS LIMITED

175 Mauldeth Road
Fallowfield
Manchester
M14 6SG
UNITED KINGDOM



is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Product(s)

Cable Types as listed below:
Context Plus XPS

Standard(s) (see Appendix for details)

BS 6387:2013 (Category CWZ)
EN 60754-1:2014
EN 61034-2:2005+A1:2013
EN 50200:2015 (Class PH30)
EN 60332-3-24:2009
EN 60332-3-25:2009

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd.

Karen Coull
Certification Scheme Manager

17 July 2019
Date of Issue

16 January 2015
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB® is a registered trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 682e-(cl-1) CONTEXT PLUS LIMITED

Issue: 02

Product name					LPCB Ref. No.
Context Plus XPS					682e/01
Nominal csa of conductor (mm ²)	Core Construction (excluding drain wire and earth)	BS 6387	EN 60754-1	EN 61034-2	EN 50200
1.0 ⁽¹⁾	2,3 & 4	C, W, Z	<0.5% HCl	>60%	PH30
1.5 ⁽¹⁾	2,3 & 4	C, W, Z	<0.5% HCl	>60%	PH30
2.5 ⁽¹⁾	2,3 & 4	C, W, Z	<0.5% HCl	>60%	PH30
4.0 ⁽²⁾	2,3 & 4	C, W, Z	<0.5% HCl	>60%	PH30

Uo/U 300/500V

Notes:

1. Solid conductor only.
2. Stranded conductor only.
3. Where the cable diameter is greater than 12mm the cable is additionally approved to EN 60332-3-24.
4. Where the cable diameter is equal to or less than 12mm the cable is additionally approved to EN 60332-3-25.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd.

Karen Coull
Certification Scheme Manager

17 July 2019
Date of Issue

16 January 2015
Date of First issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 E: enquiries@breglobal.com

LPCB is a registered trademark of the Building Research Establishment Ltd.


