



The mentioned product complies with the mentioned test requirement

# Intertek LSS Scheme Tick Mark Certificate

16LHK0204-01

In accordance with the Tick Mark Rules and Certification System 5, as defined in ISO / IEC Guide 67, we certify that the product

**Compact Range of Sounders and Visual Alarm Devices**  
is in conformity with the following standard(s)

EN54-3:2001+A1:2002+A2:2006, EN54-17:2005+AC:2007, EN54-23:2010

Report Number(s): 101504533LHD-001, 101504533LHD-003, 101504533LHD-004

## Context Plus Limited

Export House, 175 Mauldeth Road, Fallowfield, Manchester, M14 6SG, United Kingdom  
is authorised to use the Intertek Tick Mark for the LSS Scheme on the above mentioned product

This certificate is valid until:

11 August 2020

This Certificate is issued in accordance with the Certification Regulations governing its use and in reliance on the undertaking given by the Licensee and only extends to the use in respect of the goods produced to an acceptable degree of compliance with the Approval Standard. This Certificate is not transferable and remains the property of Intertek Testing and Certification Ltd.

<b>Limitations:</b>	<b>Certification body:</b> ITCL
	<b>LSS Ref:</b> LSS 0719
	<b>Issued Date:</b> 11 August 2016

Signed on behalf of Intertek, located at Leatherhead, United Kingdom



010

Technical Reviewer

Billy Blakeman  
Certification Officer

Certification Officer

Nerina Walton  
Head of Notified Body





The mentioned product  
complies with the mentioned  
test requirement

# Intertek LSS Scheme Tick Mark Certificate

16LHK0204-01

The tested product fulfills the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

## ANNEX No 1

Brand and Type/Model	Description	Factory Code
CON450A/CX/SW	Addressable sounder with isolator (white body)	CTECUK.01
CON450A/CX/SR	Addressable sounder with isolator (red body)	CTECUK.01
CON451A/CX/SW	Addressable sounder VAD with isolator (white body)	CTECUK.01
CON451A/CX/SR	Addressable sounder VAD with isolator (red body)	CTECUK.01
CON458A/CX/SW	Addressable VAD with isolator (white body)	CTECUK.01
CON458A/CX/SR	Addressable VAD with isolator (red body)	CTECUK.01



The mentioned product  
complies with the mentioned  
test requirement

# Intertek LSS Scheme Tick Mark Certificate

16LHK0204-01

The tested product fulfills the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

---

## ANNEX No 2

Models CON450A/CX/SW, CON450A/CX/SR, CON451A/CX/SW and CON451A/CX/SR have been approved to EN54-3:2001+A1:2002+A2:2006 for use with the following tones and volume settings:

Primary Tone 1 - Evacuate (550Hz for 0.5 sec, 825 Hz for 0.5 sec)  
Primary Tone 2 - Alternating (925 Hz for 0.25 sec, 626 Hz for 0.25 sec)  
Primary Tone 5 - Dutch Slow Sweep (500 Hz to 1200 Hz for 3.5 sec on, 0.5 sec off)

All tones approved at maximum volume setting only.

Models CON451A/CX/SW, CON451A/CX/SR, CON458A/CX/SW and CON458A/CX/SR have been approved to EN54-23:2010 with the following specification:

Coverage volume of W-3-3.125 when wall mounted.  
Coverage volume of C-3-8 when ceiling mounted.

Flash rate of 0.5 Hz; white flash.

All models on this certificate are compliant with EN54-17:2005+AC:2007.

All models are suitable for indoor applications.

Bases:

SBF4080000 - Mounting base for /SW variants (white body)  
SBF4080001 - Mounting base for /SR variants (red body)

---

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.