

Certificate of Product Approval

Certificate Number: 546a-(cl-6)

Issue: 02



Context Plus Limited

Export House
175 Mauldeth Road
Fallowfield
Manchester
M14 6SG
United Kingdom

is certified by BRE **Global** Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

Products

Alarm Warning Devices

CP550DB
CP550SB
CP850BSW
(refer to Appendix for details)

Standards

EN 54-3:2001 + A1:2002 + A2:2006

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

02 May 2017

Date of Issue

06 April 2017

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.



Appendix to Certificate No: 546a-(cl-6)

Issue: 02

Context Plus Limited

Certified Product	Description	LPCB Ref.No.
CP550SB	<p>Conventional Indoor Type A Sounder</p> <p>Notes:</p> <ol style="list-style-type: none"> The sounder is approved in red and white colours (-R and -W suffixes) Certified to EN 54-3: 2001 with the following selectable tones: <ul style="list-style-type: none"> 1 – LF Sweep frequency (800-1000Hz in 0.5sec) 25 – German DIN tone Sweep (1200-500Hz @ 1Hz) 27 – French tone AFNOR (554Hz for 100ms and 440Hz for 400ms) 2ndStage tone for all above (800Hz continuous tone) 11 – 2ndStage, Dutch sweep tone (500-1200Hz for 3.5s on, 0.5s off) 	546a/01
CP550DB	<p>Conventional Outdoor Type B Sounder</p> <p>Notes:</p> <ol style="list-style-type: none"> The sounder is approved in red and white colours (-R and -W suffixes) Certified to EN 54-3: 2001 with the following selectable tones: <ul style="list-style-type: none"> 1 – LF Sweep frequency (800-1000Hz in 0.5sec) 25 – German DIN tone Sweep (1200-500Hz @ 1Hz) 27 – French tone AFNOR (554Hz for 100ms and 440Hz for 400ms) 2ndStage tone for all above (800Hz continuous tone) 11 – 2ndStage, Dutch sweep tone (500-1200Hz for 3.5s on, 0.5s off) 	546a/01
CP850BSW	<p>Conventional Indoor Type A Sounder Base</p> <p>Notes:</p> <ol style="list-style-type: none"> Also approved in Off-white, Ivory and Alternative white (-O, -I, and -A suffixes) Meets the requirements of EN 54-3 at the following tone settings on low, medium and high volume settings: <ul style="list-style-type: none"> 1 – LF Sweep (800-1000Hz @ 0.5 Sec) 3 – Warble Tone BS (800-1000Hz @ 0.5 Sec) 	546a/04

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan
Verifier

02 May 2017
Date of Issue

06 April 2017
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
LPCB is a Registered Trademark of the Building Research Establishment Ltd.




Appendix to Certificate No: 546a-(cl-6)

Issue: 02

Context Plus Limited

Certified Product	Description	LPCB Ref.No.
	11 – 1 st Stage, Dutch Sweep Tone (970Hz Cont) 11 – 2 nd Stage, Dutch Sweep Tone (500-1200Hz for 3.5s on, 0.5s off) 25 – German DIN Tone (Sweep 1200-500Hz @ 1 Hz) 27 – French Tone AFNOR (554 Hz 100ms and 440Hz for 400ms) 3. Cover Plate (white) – Part no. 116-099 Cover Plate (ivory) – Part no. 116-119	

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan
Verifier

02 May 2017
Date of Issue

06 April 2017
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX
 T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com
 LPCB is a Registered Trademark of the Building Research Establishment Ltd.


