

LPCB

This is to Certify

Context Plus Ltd

Export House, 175 Mauldeth Road, Fallowfield, Manchester,
M14 6SG, UK

is authorised to use the LPCB mark in association with the
product(s) listed in this certificate and appendix.

XFP502/X/CON, XFP501/X/CON and XFP501E/X/CON
- Control and Indicating Equipment

which have complied with the requirements of the following:

EN 54-2: 1997 + A1: 2006
EN 54-4: 1997 + A1: 2002 + A2: 2006

Certificate No: 176b-(cl-2)

Issue Number: 01

Date of Issue: 13 February 2013

Signed for and on behalf of LPCB



W HUNUKUMBURE



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: www.redbooklive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through
annual review and verification. To check the authenticity of this certificate, please visit www.redbooklive.com or contact us.

LPCB

Appendix to Certificate

Certificate No: 176b-(cl-2)

Context Plus Ltd

Certified Products

LPCB Ref. No.

XFP502/X/CON Two Loop, 32 Zone Analogue addressable control and indicating equipment using Apollo Protocol, Metal housing

176b/02

Incorporating the following units:

SPF0501000 Switch mode power supply board
SPF0501201 XFP Apollo 2 Loop, Main motherboard
SPF0501200 Display board "Keypad Display"

Certified with the following options with requirements from EN 54-2:1997

7.8 Output to fire alarm device(s)
7.11 Delays to the actioning of outputs fire alarm devices and fire routing equipment
7.12.1 Dependencies on more than one alarm signal – Type A
7.12.2 Dependencies on more than one alarm signal – Type B
7.12.3 Dependencies on more than one alarm signal – Type C
7.13 Alarm counter
8.3 Fault signals from points
9.5 Disablement of each address point
10 Test condition

Notes:

- 1) Scope of approval does not include the operation of the network functionality.

Appendix Issue No: 01

Page: 2 of 4

Date of Issue: 13 February 2013

Signed for and on behalf of LPCB



W HUNUKUMBURE



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: www.redbooklive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit www.redbooklive.com or contact us.

LPCB

Appendix to Certificate

Certificate No: 176b-(cl-2)

Context Plus Ltd

Certified Products

LPCB Ref. No.

XFP501/X/CON One Loop, 32 Zone Analogue addressable control and indicating equipment using Apollo Protocol, Metal housing

176b/04

Incorporating the following units:

SPF0501000 Switch mode power supply board
SPF0501211 XFP Apollo 1 Loop, Main motherboard
SPF0501200 Display board "Keypad Display"

Certified with the following options with requirements from EN 54-2:1997

7.8 Output to fire alarm device(s)
7.11 Delays to the actioning of outputs fire alarm devices and fire routing equipment
7.12.1 Dependencies on more than one alarm signal – Type A
7.12.2 Dependencies on more than one alarm signal – Type B
7.12.3 Dependencies on more than one alarm signal – Type C
7.13 Alarm counter
8.3 Fault signals from points
9.5 Disablement of each address point
10 Test condition

Notes:

1) Scope of approval does not include the operation of the network functionality.

Appendix Issue No: 01

Page: 3 of 4

Date of Issue: 13 February 2013

Signed for and on behalf of LPCB



W HUNUKUMBURE



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: www.redbooklive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit www.redbooklive.com or contact us.

LPCB

Appendix to Certificate

Certificate No: 176b-(cl-2)

Context Plus Ltd

Certified Products

LPCB Ref. No.

XFP501E/X/CON One Loop, 16 Zone Analogue addressable control and indicating equipment using Apollo protocol, Plastic housing

176b/06

Incorporating the following units:

SPF0702480 Switch mode power supply board
SPF0501101 XFP Apollo 1 Loop, Main motherboard

Certified with the following options with requirements from EN 54-2:1997

7.8 Output to fire alarm device(s)
7.11 Delays to the actioning of outputs fire alarm devices and fire routing equipment
7.12.1 Dependencies on more than one alarm signal – Type A
7.12.2 Dependencies on more than one alarm signal – Type B
7.12.3 Dependencies on more than one alarm signal – Type C
7.13 Alarm counter
8.3 Fault signals from points
9.5 Disablement of each address point
10 Test condition

Notes:

1) Scope of approval does not include the operation of the network functionality.

Appendix Issue No: 01

Page: 4 of 4

Date of Issue: 13 February 2013

Signed for and on behalf of LPCB



W HUNUKUMBURE



LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: www.redbooklive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit www.redbooklive.com or contact us.