

## Certificate of Product Approval

Certificate Number: 176f-(cl-1)

Issue: 01

### Context Plus Limited

Export House  
175 Mauldeth Road  
Fallowfield  
Manchester M14 6SG  
United Kingdom

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

**Alarm Warning Devices**  
CON433A/CX/DR  
(refer to Appendix for details)

#### Standards

**EN 54-3:2001 + A1:2002 + A2:2006**  
**EN 54-17:2005**  
**EN 54-23:2010**

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

Peter Halligan  
Verifier

12 April 2017  
Date of Issue

12 April 2017  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)



## Appendix to Certificate No: 176f-(cl-1) Context Plus Limited

Issue: 01

Certified Product	Description	LPCB Ref.No.
CON433A/CX/DR	<p>Hi-Output Addressable Type B (outdoor) Wall Sounder VAD with Short Circuit Isolator, Deep Base (Red) (Apollo Discovery)</p> <p>Notes:</p> <ol style="list-style-type: none"> <li>Meets the requirements of EN 54-23 for the following: <ul style="list-style-type: none"> <li>- Category W-2.4-8.2</li> <li>- Flash rate 0.5Hz</li> <li>- Synchronization</li> <li>- Operating voltage range 21-28 VDC</li> </ul> </li> <li>Meets the requirements of EN 54-3 for the following: <ul style="list-style-type: none"> <li>- Evacuate, 572Hz for 0.5s, 720Hz for 0.5s</li> <li>- Alternating, 962Hz for 0.25s, 572Hz for 0.25s</li> <li>- Dutch slow sweep, 500Hz to 1200Hz for 3.5s on, 0.5s off</li> <li>- Operating voltage range 17-28 VDC</li> </ul> </li> </ol>	176f/02

**Base:**

Deep base

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for LPCB

Peter Halligan  
Verifier

12 April 2017  
Date of Issue

12 April 2017  
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and are issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

