

UQGS.S24128 - HEAT-AUTOMATIC FIRE DETECTORS

Heat-automatic Fire Detectors

See General Information for Heat-automatic Fire Detectors

CONTEXT PLUS LTD

S24128

Progress House
 Newby Industrial Estate
 Newby Road , Hazel Grove.
 Stockport, SK7 5DA UNITED KINGDOM

Model No.	Type	Compatibility Restrictions	Contact Arrangement	Temp Range (°F)	Spacing (Ft)	
					Smooth Ceiling	to Wall or Partition
55000-139 IMC	FT/ROR	D2	-	135	50	25
55000-145 IMC	FT/ROR	D2	-	200	50	25
58000-450IMC	FT/ROR	*1	-	135 (m1)	70	35
				150 (m2 / m3)	70	35
				200 (m4 / m5)	70	35

Base Model	Related Detector	Control Unit Compatibility Restrictions
45681-200 IMC	55000-139 IMC, 55000-145-IMC	#1
45681-210IMU	58000-450IMC	#1

D2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

#1 - For connection to Listed Control units Models ZXa and ZXe, manufactured by Morley IAS, employing software revision greater than 684aU0.

*1 - For connection to Listed Control units Models ZXa and ZXe, manufactured by Morley IAS, employing software revision greater than 684aU0.

FT/ROR - Fixed temperature/rate of rise combination

Trademark and/or Tradename: **Context plus**