

**MANUAL  
HFC-227ea  
DISCHARGE  
STATION**

**FLASHING LIGHT  
MEANS HFC-227ea  
HAS DISCHARGED**

**CAUTION**  
**ROOM PROTECTED  
BY HFC-227ea  
IN CASE OF FIRE KEEP DOOR CLOSED**

**CAUTION**  
WHEN ALARM SOUNDS  
VACATE ROOM, FIRE SUPPRESSION  
SYSTEM BEING DISCHARGED

**CAUTION**  
DO NOT ENTER ROOM WHEN  
ALARM SOUNDS. FIRE SUPPRESSION  
SYSTEM BEING DISCHARGED

**CAUTION**  
OPERATION OF MANUAL STATION WILL  
RESULT IN IMMEDIATE DISCHARGE  
OF FIRE SUPPRESSION SYSTEM

### Description

Instructional signs should be supplied in order to provide for a system in which the function of all devices is easy to understand. Context Plus offers several different "standard" signs to comply with NFPA and other industry requirements. All signs are made of durable plastic and backed with a strong adhesive for easy installation. Signs are typically installed at all entrances [e.g. CAUTION – Room Protected By HFC-227ea] and near any devices for which the additional explanation is helpful. Custom made instructional signs are available upon request.

#### MANUAL DISCHARGE STATION SIGN (CP 50233)

The purpose of the Manual Discharge Station Sign is to identify the manual pull station as the place where the HFC-227ea can be manually discharged. It also minimizes the possibility of the manual pull station being mistaken for a fire alarm device. The sign has a dimension of 4" x 4" x 1/16" (100 x 100 x 1.5 mm) and is made of plastic with white lettering on a red background. The Manual Discharge Station Sign should be located in the proximity of the manual pull station for quick positive identification.

#### FLASHING LIGHT SIGN (CP 50234)

The purpose of the Flashing Light Sign is to attract public notice/attention in the event of a HFC-227ea discharge. The sign has a dimension of 7" x 4 1/4" x 1/16" (178 x 108 x 1.5 mm) and is made of plastic with white lettering on a red background. This will alert personnel when HFC-227ea has been discharged and allow them to take appropriate actions.

#### YELLOW CAUTION SIGN (CP 50235)

The purpose of the Caution Sign is to alert personnel that the room is protected by HFC-227ea and that all doors should be kept closed in the event of fire. The sign has a dimension of 14" x 10" x 1/16" (356 x 254 x 1.5 mm) and constructed of plastic with a yellow background. The Caution Sign should be conspicuously located in any rooms where HFC-227ea protection is being provided.

Context Plus offers three additional standard CAUTION signs to comply with NFPA and authorities having jurisdiction to provide caution and direction to various system component devices. All signs are made of durable plastic, backed with strong adhesive for easy installation. Signs are also pre-drilled at each corner for screw fasteners if desired. Signs are typically installed on doors, near alarm devices, next to controls, etc. All signs have a dimension of 3 1/2" x 7 1/2" x 1/16" with white lettering on a red background.

#### CAUTION ( When Alarm Sound ... ) (CP 50230)

The purpose of this caution sign is to alert personnel to evacuate the protected area. The sign should be conspicuously located near alarm devices.

#### CAUTION ( Do Not Enter Room ... ) (CP 50231)

The purpose of this caution sign is to prevent personnel from entering a protected area. The sign should be conspicuously located outside the entrance door to the protected area.

#### CAUTION ( Operation of Manual Station Will ... ) (CP 50232)

The purpose of this caution sign is to instruct personnel as to use of the Agent Release Manual Pull Station. This sign should be installed adjacent to all Agent Release Manual Pull Stations.